Revised 7/01

THERMOPLASTIC SUMP-GARD® SGL VERTICAL CENTRIFUGAL PUMP

GENERAL

Pump to be constructed with all wetted components either of polyvinyl chloride (PVC), polypropylene (PP), or polyvinylidene fluoride (PVDF) thermoplastic materials. Flows to 1450 GPM (330m³/hr). Heads to 245 Ft (85m). Temperatures to 275°F (135°C). Sump depths to 50 Ft (15m).

CASING AND CASING COVER

Injection molded homogeneous thermoplastic material selected for compatibility with the fluids being pumped.

• IMPELLER

Thermoplastic material injection molded with an embedded dynamically balanced stainless steel insert with radial vanes. It shall be closed or semiopen vane design, with keyway for mounting on the shaft to assure positive drive.

SHAFT

Alloy steel shaft sleeved with a thermoplastic material to isolate it from the fluid. Shaft to be supported above the coverplate by heavy-duty external ball bearings and be of segmented design to facilitate shipping, installation and maintenance of long lengths. All couplings and shaft connectors to be isolated from the fluid by thermoplastic sleeving.

VERTICAL SUPPORT COLUMN AND DISCHARGE PIPE

Fabricated of heavy-sectioned thermoplastic. The upper portion of the column to be fitted with a nonmetallic vapor seal to protect motor and ball bearings in mounting bracket.

• COVER PLATE

Sized and shaped to fit the sump, and furnished in the same or compatible thermoplastic material as the pump. All hardware below the coverplate to be nonmetallic.

MOTOR MOUNTING BRACKET

Precision-machined mounting surfaces for a rabbet fit to automatically align pump and motor coupling. The assembly is to be designed to house regreasable ball bearing(s) for positioning and locking the shaft into position and to allow adjustable impeller clearance without removing the pump from installation. Cast iron motor mounting bracket to be painted with a two-part chemical resistant epoxy resin or similar resistant coating material.

• SUCTION STRAINER

Strainer basket to be provided where required in the same material as the hydraulic head.

• FACTORY TESTING

Each pump to be tested to assure performance at conditions of service. Test data to be permanently recorded and retrievable on request.

www.vanton.com

